



TEBAR®

Test Belgelendirme Araştırma ve Geliştirme Ticaret A.Ş.

Şerif Ali Çiftliği Hendem Cd. No:58
Kat 1 Yukarı Dudulu 34775
Ümraniye – İstanbul

Tel : +90 216 420 47 52
Faks : +90 216 466 31 52

www.tebar.com.tr • info@tebar.com.tr

CLASSIFICATION REPORT FOR LIGHT TRANSMITTING FLAT MULTIWALL POLYCARBONATE (PC) SHEETS EXPOSED TO EXTERNAL FIRE – EN 13501-5

Report Number: SR15-07

Owner: POLİNET LTD. ŞTİ.

Product Definition : Light transmitting flat multiwall polycarbonate (PC) sheets

Trade Mark: EasyLux / MasterLux / ThermoLux PC Multiwall Panel

Product Standard : EN 16153

Production Plant : İstanbul Mermerciler Yapı Koop. San. Sit. 5.Cadde No:20 Köseler Köyü Dilovası
Gebze - Kocaeli

Prepared by Kemal ÇATKIN/ Laboratory As. 		Reviewed by Gülsüm ÖZGÜN/ Head of Testing Laboratory 
--	---	--

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürlü raporlar geçersizdir.

Order Number: İ15000016	Report Number: SR15-07	Page Number 1/5	Report Date: 04.03.2015(dd/mm/yyyy)
-----------------------------------	----------------------------------	---------------------------	---

FR.078/02/04.01.2012



TEBAR®

Test Belgelendirme Araştırma ve Geliştirme Ticaret A.Ş.

Şerif Ali Çiftliği Hendem Cd. No:58
Kat 1 Yukarı Dudulu 34775
Ümraniye – İstanbul

Tel : +90 216 420 47 52
Faks : +90 216 466 31 52

www.tebar.com.tr • info@tebar.com.tr

1. Introduction:

This classification report defines the classification of transparent PC (polycarbonate) multi-wall sheet assigned to "EasyLux / MasterLux / ThermoLux PC Multiwall Panel" produced by "POLİNET LTD. ŞTİ." in accordance with procedures given in EN 13501-5:2005+A1:2009.

2. Details of classified product:

2.1. General information:

The transparent PC (polycarbonate) multi-wall sheet manufactured by "POLİNET LTD. ŞTİ." with a trademark of "EasyLux / MasterLux / ThermoLux PC Multiwall Panel" is used for internal and external roofs, walls and ceilings.

2.2. Description of the product:

The transparent PC (polycarbonate) multi-wall sheet assigned to "EasyLux/MasterLux /ThermoLux PC Multiwall Panel" produced by "POLİNET LTD. ŞTİ." is described below depends on manufacturer's declarations.

Ürünün Markası	:	EasyLux / MasterLux / ThermoLux PC Multiwall Panel
Origin of the product	:	PC (polycarbonate)
Reinforcement	:	-
Thickness	:	30-40mm
Lower surface covering	:	-
Upper surface covering	:	-
Colour	:	Transparent, Opal
Fire Retardant Type/Usage	:	-

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürsüz raporlar geçersizdir.

Order Number:	Report Number:	Page Number	Report Date:
İ15000016	SR15-07	2/5	04.03.2015(dd/mm/yyyy)

FR.078/02/04.01.2012





TEBAR®

Test Belgelendirme Araştırma ve Geliştirme Ticaret A.Ş.

Şerif Ali Çiftliği Hendem Cd. No:58
Kat 1 Yukarı Dudulu 34775
Ümraniye – İstanbul

Tel : +90 216 420 47 52
Faks : +90 216 466 31 52

www.tebar.com.tr • info@tebar.com.tr

2.3. Product Standard:

EN 16153: Light transmitting flat multiwall polycarbonate (PC) sheets for internal and external use in roofs, walls and ceilings - Requirements and test methods.

3. Test reports and test results in support of this classification:

3.1. Test Report:

Name of laboratory	Name of sponsor	Test report ref. no.	Test method
TEBAR A.Ş.	POLINET LTD. ŞTİ.	R1500037	ENV 1187-2

3.2. Test results:

Test Conditions: Test specimen is mounted at a roof pitch of 30° to horizontal plane and a forced airflow is passing over the exposed surface. A burning wooden crib is placed on the surface of the specimen.

Test Pitch: Roof pitch of 30° to horizontal plane

Substrate: -

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürsüz raporlar geçersizdir.

Order Number:	Report Number:	Page Number	Report Date:
İ15000016	SR15-07	3/5	04.03.2015(dd/mm/yyyy)

FR.078/02/04.01.2012





TEBAR®

Test Belgelendirme Araştırma ve Geliştirme Ticaret A.Ş.

Şerif Ali Çiftliği Hendem Cd. No:58
Kat 1 Yukarı Dudulu 34775
Ümraniye – İstanbul

Tel : +90 216 420 47 52
Faks : +90 216 466 31 52

www.tebar.com.tr • info@tebar.com.tr

Test Results for EasyLux / MasterLux / ThermoLux PC Multiwall Panel according to EN 13501-5

Parameter	Criteria		Test Results					Compliance
	Mean	Max	Spe. 1	Spe. 2	Spe. 3	Mean	Max	
Damaged length at 2 m/s – roof covering	≤ 0,550 m	≤0,800 m	0,500	0,510	0,518	0,509	0,518	Y
Damaged length at 2 m/s – substrate	≤ 0,550 m	≤0,800 m	-	-	-	-	-	Y
Damaged length at 4 m/s – roof covering	≤ 0,550 m	≤0,800 m	0,500	0,400	0,380	0,427	0,500	Y
Damaged length at 4 m/s – substrate	≤ 0,550 m	≤0,800 m	-	-	-	-	-	Y

4. Classification and field of application:

4.1. Reference of classification:

This classification has been carried out in accordance with clause 6.5.3, 7., 8.2. and 9. of EN 13501-5: 2005+A1:2009 "Fire classification of construction products and building elements - Part 5: Classification using data from external fire exposure to roofs tests".

4.2. Classification:

The transparent PC (polycarbonate) multi-wall sheet produced by "POLİNET LTD. ŞTİ." with trademark of "EasyLux / MasterLux / ThermoLux PC Multiwall Panel" in relation to its external fire performance classified as below.

B_{ROOF} (t2)

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürsüz raporlar geçersizdir.

Order Number:	Report Number:	Page Number	Report Date:
İ15000016	SR15-07	4/5	04.03.2015(dd/mm/yyyy)

FR.078/02/04.01.2012





TEBAR®

Test Belgelendirme Araştırma ve Geliştirme Ticaret A.Ş.

Şerif Ali Çiftliği Hendem Cd. No:58
Kat 1 Yukarı Dudulu 34775
Ümraniye – İstanbul

Tel : +90 216 420 47 52
Faks : +90 216 466 31 52

www.tebar.com.tr • info@tebar.com.tr

4.3. Field of application:

4.3.1. This classification is only valid for transparent PC (polycarbonate) multi-wall sheet which are to be used for walls, ceilings, roof heat insulation, sound insulation.

4.3.2. This classification is only valid for the products which complies with definition in clause 2 and produced in the manufacturing plant defined in this report.

5. Warning and Limitations:

5.1. This classification report does not represent type of approval or certification of the product.

5.2. This classification report is valid for 5 years period until **04th March 2020**.

Report	Name	Signature*	Date
Prepared by	Kemal ÇATKIN		04.03.15
Reviewed by	Gülsüm ÖZGÜN		04.03.2015
*For and on behalf of "POLİNET LTD. ŞTİ."			

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid.

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürsüz raporlar geçersizdir.

Order Number:	Report Number:	Page Number	Report Date:
İ15000016	SR15-07	5/5	04.03.2015(dd/mm/yyyy)

FR.078/02/04.01.2012

